

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge Protective Devices

Name and address of the applicant

JIAXING BIPENG LIGHTING COMPANY LIMITED
2F No.15 Building, Chuanhua Smart Port, No.4567 Hangzhouwan Avenue,
Haiyan County, Jiaxing City, Zhejiang, China

Name and address of the manufacturer

JIAXING BIPENG LIGHTING COMPANY LIMITED
2F No.15 Building, Chuanhua Smart Port, No.4567 Hangzhouwan Avenue,
Haiyan County, Jiaxing City, Zhejiang, China

Name and address of the factory

JIAXING BIPENG LIGHTING COMPANY LIMITED
2F No.15 Building, Chuanhua Smart Port, No.4567 Hangzhouwan Avenue,
Haiyan County, Jiaxing City, Zhejiang, China*When more than one factory*☐ Additional information on page 2

Ratings and principal characteristics

Product data

Ratings:

Test class II / Type 2 & Test class III / Type 3;

Uc: 320 V~ (L-N), 255 V (N-PE); In: 6 kA (L-N, N-PE); Uoc: 12 kV

Up: 1.5 kV (L-N), 2.5 kV (N-PE); Iscrr: 300 A; IP20/IP66;

See page 7 of Report No. 6248794.50 for detail.

Trademark / Brand (if any)



BP

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SPD10KV-1, SPD10KV-1/II, SPD10KV-3/P, SPD10KV-3/P/II,
SPD10KV-3/P/M, SPD10KV-3/S and SPD10KV-3/S/II

Additional information

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61643-11:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

6248794.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-05-15

Signature: Carol Jwo